

42
Ordinance # 86
PRESCRIBING GENERAL RULES AND STANDARD
SPECIFICATIONS FOR STREET AND SIDEWALK
WORK IN THE TOWN OF SAN ANSELMO.

Repealed by Ordinance # 88
Page 1 of 1

The Board of Trustees of the Town of San Anselmo do ordain
as follows:

CONCRETE SIDEWALKS.

Section 1: The width of all concrete sidewalks shall be determined by the Board of Trustees.

Section 2: The thickness of all concrete sidewalks shall be at least Three (3) inches after completion.

Prepare the surface of the ground wherever concrete sidewalks are to be constructed, by excavating or filling to the required depth or sub-grade, care being taken to ram or roll the surface so prepared, so as to present a smooth and firm bearing to receive the concrete.

The base or first layer of concrete shall have a thickness for ramming or rolling of not less than Two and one-half (2 1/2) inches, and shall be prepared and composed as follows: To One (1) part of best Portland cement there shall be Five (5) parts of clean hard broken rock, ranging in size from One-half (1/2) inch to One and one-half (1 1/2) inches in diameter, and Two (2) parts of clean sharp sand. The whole to be thoroughly mixed dry, water added, and again thoroughly mixed ready for the work in hand. This mixture to be immediately placed in position and ramed or rolled until the water comes to the surface. Gravel conforming to the same mesh composition may be substituted for rock.

The top or surface layer of concrete shall have a thickness of One-half (1/2) inch, and shall be composed of equal parts of best Portland cement and clean sharp sand, thoroughly mixed dry, the proper amount of water added, and finished by a trowel to a perfectly smooth surface, marked off in squares not exceeding Two and one-half (2 1/2) feet in any direction.

All concrete used in the work herein mentioned shall be thoroughly mixed, and no concrete shall be used that has been rejected.

#86

WORK ON GRAVEL SIDEWALKS.

Section 4: Sand or gravel sidewalks may be laid at the discretion of the Board of Trustees. Sand or gravel used for said purpose shall be such as will pass a Three-quarter (3/4) inch screen. Sidewalks of this class to have a thickness of Two and one-half (2 1/2) inches.

The finished surface of all sidewalks shall conform to the lines and grades which shall be furnished by the Town Engineer, and the direction of the Board of Trustees of the Town of San Anselmo.

All work to be done to the entire satisfaction of the Town Engineer, or the Inspector duly appointed to act under him by the Board of Trustees.

All work shall be guaranteed against cracks or settlement for a period of One (1) year, and the Contractor will be required to furnish a bond for the same.

WOODEN CURBS.

Section 5: Between curbs are to be constructed of sound black hard redwood planks not less than Three (3) inches thick, and Twelve (12) inches wide.

The curbing must be carefully set to the proper line and grade with earth or other material upon either side to hold it in place, well compacted.

ROCK GUTTERWAYS.

Section 6: The bottom of the excavation for rock gutterways is to be at least Seven (7) inches below the surface of the finished gutterways.

The gutterways are to extend at least Two and one-half (2 1/2) feet from the curbs, and are to be constructed of large flat stones having a thickness of not less than Four (4) inches. These stones are to be laid with upper surfaces evened in such a way that the center of the gutterway will be depressed Four (4) inches below its edges.

The center line of the gutterways is to be Eight (8) inches below the required top of curb, except in cases where otherwise directed by the Board of Trustees.

an e 6

The stones for the gutterways are to be laid on a bed of concrete Three (3) inches thick, composed of One (1) part cement, Two (2) parts sand, and Five (5) parts fine broken rock.

The stones are to be placed by hand, being imbedded in the concrete while the same is still fresh. They are to be placed closely and compactly, and the spaces between them are to be filled with spawls and grouted with a thin cement mortar, composed of One (1) part Portland cement to One (1) part of sand.

All rock for gutterways must be hard and durable, clean and free from clay and dirt.

Section 6: This Ordinance shall take effect and be in force immediately from and after its passage.

Passed and adopted this 14th day of June, 1911, by the following vote:

Ayes: Trustees Gagan, Shrader, Stratford and Whitaker.

Noes: None.

Absent: (Trustee Jones.)

Attest:

W.A. Moore
Town Clerk.

Charles R. Gagan
President of the Board of
Trustees of the Town of
San Anselmo. *Pro Tem.*

The foregoing Ordinance hereby approved, this

14th day of June, 1911.

Charles R. Gagan
President of the Board of
Trustees of the Town of
San Anselmo. *Pro Tem.*

Ordinance #86

STATE OF CALIFORNIA }
COUNTY OF MARIN, } ss.
TOWN OF SAN ANSELMO }

I, A. A. MOORE, Town Clerk of the Town of San Anselmo and ex-officio Clerk of the Board of Trustees of said Town, hereby certify that the foregoing is a full, true and correct copy of an ordinance regularly and duly passed at a regular monthly meeting of the Board of Trustees of said Town more than five days after the date of its introduction.

That the said ordinance was numbered 86 and entitled Prescribing general rules and standard specifications for street and sidewalk work in the Town of San Anselmo

That the said ordinance was thereafter duly posted in accordance with law and the order of said Board of Trustees in three conspicuous places in said Town.

In witness, whereof, I have hereunto set my hand and affixed the Corporate Seal of the Town of San Anselmo, at my office in said Town, this 16th day of June 1911.

A. A. Moore

CLERK OF THE TOWN OF SAN ANSELMO.

Repealed - see Ordinance No 88.